Accessibility Audit undertaken Wednesday 7th September 2022

Present: Councillor Lizeta Fellows, Geoff Squibb (manual wheelchair user) Disability Cornwall, Milly Southworth Town Clerk & RFO, Phil Griffiths Operations Manager

Location/Premises	Accessible ?	Comments	Recommendations	Timescale (short/medium/long)
Borough Park Play Park	✓	No network of accessible pathways around the play equipment	Install pathways between the play park equipment. Use matting for accessible pathways	Medium
	~		Install additional bench near to	Medium
	~	The gate opens outwards and therefore is difficult to open from a wheelchair user's perspective.	Consider two-way gate to be installed at ALL locations	Short
Chestnut Close Play Park	x	Unable to access from any direction, due to surface being grass/mud.	Consider installation of matted accessible pathway (firm footing 1200cm wide)	Long
	x	No drop kerb to the pavement	Install drop kerb to the pavement	Long
Car parking area and land to access Bénodet Park	✓		Install accessible car parking spaces (two)	Long

				1
	√	Areas of the land have been recently been re-tarmacked, creates difficulty to access the Park, public conveniences and other lower area of The Lawn	"dangerous, uneven and lethal"	Long
Skate Park	✓	Benches unaccessible	When replacing, consider acceesible benches instead	Long
Bénodet Park	\checkmark	would be useful for the entrance to display an Accessible Drop Off sign	Install an Accessible Drop Off sign	Short
Thanckes Park Play Park	x		Install an accessible, sloping ramp alongside the wall, with the gated entrance moved to the start of the ramp. Handrails required.	Medium
		No network of accessible pathways around the play equipment	Install pathways between the play park equipment. Use matting for accessible pathways	Medium
Bénodet Park Public Conveniences	~	Door handle slightly too high to reach	Relocate door handle on the accessible toilet	Short
Tennis Courts	x	Unable to access	Discussed councils proposals for top court to be accessible, agreed all proposals, including 'cutting away' alongside the net	
Cambridge Field	✓	Able to access from top new entrance, although difficulty with returning to the pavement.	Suggest updating the entrance to create a flat surface, followed a graded slop, then a flat surface. This could be continued into the park as part of phase II plans.	Long

	√	No network of accessible pathways around the play equipment Original entrance, metal handrail prevents access	Install pathways between the play park equipment. Use matting for accessible pathways Remove handrail	Long Short
Torpoint Library & Community Hub	✓	Double yellow lines outside, pleasing to see, however, no lines on the curb, which means disabled drivers can park across the double yellow lines for up to three hours Access ramp to get to the outside space	Highways guidance needed to improve Ramp was accessible, doors required to be pinned back properly	Short
	✓ ✓	Hearing Loop Toilet facility	Consider installtion of mobile hearing loop Accessible	Medium N/A
Council Chambers	✓ ✓ ✓	Accessible ramp to the Main Hall - slopes to the left when returning to the Buller Road door Accessible ramp to the Main Hall - slopes to the left when returning to the Buller Road door		N/A Medium N/A N/A
	✓	Toilet facility	Accessible	N/A

	✓	distnguish change in gradiant	Install coloured carpet tape to highlght the change in gradient	Short
	\checkmark	Entrance and exit to building at Grace and Glamour entrance		N/A
	√	No bobbled stones to indicate dropped kerbs	surfaces.pdf	
	\checkmark	Hearing Loop	Consider installtion of mobile hearing loop	Medium
Other		Access Statement	Publish an Access Statement on the website (with link to videos uploaded to YouTube)	Short